



**BID BULLETIN NO. 3**  
**For LBP-HOBAC-ITB-GS-20180315-01**

**PROJECT** : **One (1) Lot Supply and Installation of 200 Sets 2.0 KVA Uninterruptible Power Supply at LANDBANK Field Units and Offsite ATMs**

**IMPLEMENTOR** : **Procurement Department**


**DATE** : **May 3, 2018**

This Bid Bulletin is issued to modify, amend or clarify items in the Bid Documents. This shall form an integral part of the Bid Documents.

The modifications, amendments or clarifications are as follows:

- 1) The deadline of submission and the schedule of opening of eligibility/technical and financial documents/proposals for the above project is re-scheduled to **May 10, 2018, 11:00 A.M.** at the Procurement Department, 25th Floor, LANDBANK Plaza Building, 1598 M. H. Del Pilar corner Dr. Quintos Streets, Malate, Manila.
- 2) Clarification on bidder's query:

BIDDER'S QUERY	LANDBANK'S RESPONSE
<p>1) The maximum eight (8) pieces x 7.2 AH will not reach up to fifteen (15) minutes at full load, instead, it can reach up to 7-8 minutes only. Does that mean the wattage of full load is lower? How many watts?</p> <p>2) If the requirement says "maximum at eight (8) pieces x 7.2 AH", does that mean LANDBANK will accept four (4) or six (6) pieces 7.2 AH configuration? What will be the basis of compliance?</p>	<ul style="list-style-type: none"> <li>• The considered full load capacity is for ATM load only which is 700 to 900 watts and not the full load capacity of the UPS unit.</li> <li>• The UPS unit with less than eight (8) batteries is acceptable provided that the fifteen (15) minutes back-up time will be complied with.</li> </ul>

  
**ALWIN I. REYES, CSSP**  
 Assistant Vice President  
 Head, Procurement Department and  
 HOBAC Secretariat